



Part of MSHA Approval No. 18-A150002-0

DO NOT CHANGE WITHOUT MSHA APPROVAL

1. The Model TX6355 Sentro Wireless Gas Monitor is MSHA approved for use with the Energizer E95 battery only.
2. Do not disassemble in an area where permissibility is required, except to change eModules.
3. The Model TX6355 Sentro Wireless Gas Monitor is not to be used as an air quality detector per 30 CFR 75.320.
4. Maintain 40 inches between the Model TX6355 Sentro Wireless Gas Monitor and any blasting circuits, explosives and detonators.
5. Only equipment with model number TX6355.04.02 is approved by QPS (NRTL tested) to ANSI/ISA 92.00.01 (Toxic Gas Performance) for CO gas detection, and is therefore accepted by MSHA for compliance with 30CFR 75.351 or 75.1103. Equipment with part number TX6355.04.01 is not accepted by MSHA for compliance with 30CFR 75.351 or 75.1103.

Note: TX6355.04.02 must only be fitted with a CO sensing eModule with part number TX6350.04.250.50 or TX6350.04.250.500.

Issue	A							TX6355.04.nn Sentro Wireless Gas Detector - Conditions of Use			
ECR	4298										
App'd	AH							Document No: P5596.1800			
Date	04/04/16							Dr'n AH	01/04/16	Ch'd NC	01/04/16

